

Tower Power Station

Licence Number: 5357

EDL CSM (NSW) PTY LTD

PO BOX 4046

Licence Holder: Eight Mile Plains 4113

Tower Coal Seam Methane Power Station

Douglas Park Drive

Licensee Address: Douglas Park NSW 2569

Month: Mar-12

Location of monitoring point	Sampled	Obtained	Published	Pollutant	Units of measure	Monitoring frequency required by licence	No. of times measured during month	Min. value	Mean value	Max. Value
Point 10 - Ambient air and weather monitoring station	-	-	-	Nitrogen Oxides	Parts per billion	Continuous	Continuous	2	8	26
	-	-	-	Ozone	Parts per billion	Continuous	Continuous	10	15	20
Point 13 - Air emissions monitoring	-	-	-	Nitrogen Oxides	Parts per million	Continuous	Continuous	753	784.3	809
Point 11 - First Flush Effluent quality monitoring	-	-	-	Oil and Grease	Milligrams per litre	Weekly during any discharge	1	No visual		
	-	-	-	pH		Weekly during any discharge	1	8.1		
Point 12 - Process Water Effluent quality monitoring	14/03/2012	28/03/2012	30/06/2012	Oil and Grease	Milligrams per litre	Monthly	1	<3		
	14/03/2012	28/03/2012	30/06/2012	pH		Monthly	1	6.99		