

Tower Power Station

Licence Number: 5357

EDL CSM (NSW) PTY LTD
PO BOX 4046

Licence Holder: Eight Mile Plains 4113

Tower Coal Seam Methane Power Station
Douglas Park Drive

Licensee Address: Douglas Park NSW 2569

Month: May-12

Location of monitoring point	Sampled	Obtained	Published	Pollutant	Units of measure	Monitoring frequency required by licence	No. of times measured during month	Min. value	Mean value	Max. Value
Point 10 - Ambient air and weather monitoring station	-	-	-	Nitrogen Oxides	Parts per billion	Continuous	Continuous	1	10	107
	-	-	-	Ozone	Parts per billion	Continuous	Continuous	-1	14	30
Point 13 - Air emissions monitoring	-	-	-	Nitrogen Oxides	Parts per million	Continuous	Continuous	Max NOx emission rate did not exceed 2132g/min		
Point 11 - First Flush Effluent quality monitoring	-	-	-	Oil and Grease	Milligrams per litre	Weekly during any discharge	3	No visual		
	-	-	-	pH		Weekly during any discharge	3	7.8	7.83	7.9
Point 12 - Process Water Effluent quality monitoring	1/05/2012	7/06/2012	30/06/2012	Oil and Grease	Milligrams per litre	Monthly	1	3		
	1/05/2012	7/06/2012	30/06/2012	pH		Monthly	1	7.3		