

**Tower Power Station**

**Licence Number:** 5357

EDL CSM (NSW) PTY LTD  
PO BOX 4046

**Licence Holder:** Eight Mile Plains 4113

Tower Coal Seam Methane Power Station  
Douglas Park Drive

**Licensee Address:** Douglas Park NSW 2569

**Month:** Sep-12

Location of monitoring point	Sampled	Obtained	Published	Pollutant	Units of measure	Monitoring frequency required by licence	No. of times measured during month	Min. value	Mean value	Max. Value
<b>Point 10</b> - Ambient air and weather monitoring station	-	12/10/12	16/10/12	Nitrogen Oxides	Parts per billion	Continuous	Continuous	0	16	402
	-	12/10/12	16/10/12	Ozone	Parts per billion	Continuous	Continuous	-1	22	50
<b>Point 13</b> - Air emissions monitoring	-	-	16/10/12	Nitrogen Oxides	Parts per million	Continuous	Continuous	Max NOx emission rate did not exceed 2132g/min		
<b>Point 8</b> - First Flush Effluent quality monitoring	-	-	16/10/12	Oil and Grease	Milligrams per litre	Weekly during any discharge	1	No visual		
	-	-	16/10/12	pH		Weekly during any discharge	1	7.8		
<b>Point 9</b> - Process Water Effluent quality monitoring	3/09/12	2/10/12	16/10/12	Oil and Grease	Milligrams per litre	Monthly	1	4		
	3/09/12	2/10/12	16/10/12	pH		Monthly	1	7.56		