

**Tower Power Station**

**Licence Number:** 5357

EDL CSM (NSW) PTY LTD  
PO BOX 4046

**Licence Holder:** Eight Mile Plains 4113

Tower Coal Seam Methane Power Station  
Douglas Park Drive

**Licensee Address:** Douglas Park NSW 2569

**Month:** Nov-12

Location of monitoring point	Sampled	Obtained	Published	Pollutant	Units of measure	Monitoring frequency required by licence	No. of times measured during month	Min. value	Mean value	Max. Value
Point 10 - Ambient air and weather monitoring station	-	12/12/12	19/12/12	Nitrogen Oxides	Parts per billion	Continuous	Continuous	0	8	84
	-	12/12/12	19/12/12	Ozone	Parts per billion	Continuous	Continuous	0	22	79
Point 13 - Air emissions monitoring	-	-	19/12/12	Nitrogen Oxides	Parts per million	Continuous	Continuous	Max NOx emission rate did not exceed 2132g/min		
Point 8 - First Flush Effluent quality monitoring	-	-	19/12/12	Oil and Grease	Milligrams per litre	Weekly during any discharge	Not required			
	-	-	19/12/12	pH		Weekly during any discharge	Not required			
Point 9 - Process Water Effluent quality monitoring	2/11/12	14/11/12	28/11/12	Oil and Grease	Milligrams per litre	Monthly	1	<3		
	2/11/12	14/11/12	28/11/12	pH		Monthly	1	7.46		