

Tower Power Station

Licence Number: 5357

EDL CSM (NSW) PTY LTD
PO BOX 4046

Licence Holder: Eight Mile Plains 4113

Tower Coal Seam Methane Power Station
Douglas Park Drive

Licensee Address: Douglas Park NSW 2569

Month: Dec-12

Location of monitoring point	Sampled	Obtained	Published	Pollutant	Units of measure	Monitoring frequency required by licence	No. of times measured during month	Min. value	Mean value	Max. Value
Point 10 - Ambient air and weather monitoring station	-	11/01/13	18/01/13	Nitrogen Oxides	Parts per billion	Continuous	Continuous	0	10	111
	-	11/01/13	18/01/13	Ozone	Parts per billion	Continuous	Continuous	0	19	59
Point 13 - Air emissions monitoring	-	-	9/01/13	Nitrogen Oxides	Parts per million	Continuous	Continuous	Max NOx emission rate did not exceed 2132g/min		
Point 8 - First Flush Effluent quality monitoring	-	-	9/01/13	Oil and Grease	Milligrams per litre	Weekly during any discharge	1	No visual		
	-	-	9/01/13	pH		Weekly during any discharge	1	8.1		
Point 9 - Process Water Effluent quality monitoring	3/12/12	12/12/12	19/12/12	Oil and Grease	Milligrams per litre	Monthly	1	<3		
	3/12/12	12/12/12	19/12/12	pH		Monthly	1	7.49		