

Tower Power Station

Licence Number: 5357

EDL CSM (NSW) PTY LTD
PO BOX 4046

Licence Holder: Eight Mile Plains 4113

Tower Coal Seam Methane Power Station
Douglas Park Drive

Licensee Address: Douglas Park NSW 2569

Month: Apr-13

Location of monitoring point	Sampled	Obtained	Published	Pollutant	Units of measure	Monitoring frequency required by licence	No. of times measured during month	Min. value	Mean value	Max. Value
Point 10 - Ambient air and weather monitoring station	-	21/05/13	28/05/13	Nitrogen Oxides	Parts per billion	Continuous	Continuous	0	12	137
	-	21/05/13	28/05/13	Ozone	Parts per billion	Continuous	Continuous	-1	15	57
Point 13 - Air emissions monitoring	-	-	29/04/13	Nitrogen Oxides	Parts per million	Continuous	Continuous	Max NOx emission rate did not exceed 2132g/min		
Point 8 - First Flush Effluent quality monitoring	-	-	29/04/13	Oil and Grease	Milligrams per litre	Weekly during any discharge	2	No visual		
	-	-	29/04/13	pH		Weekly during any discharge	2	7.2	7.4	7.6
Point 9 - Process Water Effluent quality monitoring	2/04/13	15/04/13	29/04/13	Oil and Grease	Milligrams per litre	Monthly	1	9		
	2/04/13	15/04/13	29/04/13	pH		Monthly	1	7.26		