

**Tower Power Station**

**Licence Number:** 5357

EDL CSM (NSW) PTY LTD  
PO BOX 4046

**Licence Holder:** Eight Mile Plains 4113

Tower Coal Seam Methane Power Station  
Douglas Park Drive

**Licensee Address:** Douglas Park NSW 2569

**Month:** Jul-13

Location of monitoring point	Sampled	Obtained	Published	Pollutant	Units of measure	Monitoring frequency required by licence	No. of times measured during month	Min. value	Mean value	Max. Value
<b>Point 10</b> - Ambient air and weather monitoring station	-	14/08/13	15/08/13	Nitrogen Oxides	Parts per billion	Continuous	Continuous	0	10	82
	-	14/08/13	15/08/13	Ozone	Parts per billion	Continuous	Continuous	-1	15	30
<b>Point 11</b> - Air emissions monitoring	-	-	9/08/13	Nitrogen Oxides	Parts per million	Continuous	Continuous	Max NOx emission rate did not exceed 2132g/min		
<b>Point 8</b> - First Flush Effluent quality monitoring	-	-	9/08/13	Oil and Grease	Milligrams per litre	Weekly during any discharge	2	No visual		
	-	-	9/08/13	pH		Weekly during any discharge	2	8.2	8.35	8.5
<b>Point 9</b> - Process Water Effluent quality monitoring	1/07/13	21/07/13	22/07/13	Oil and Grease	Milligrams per litre	Monthly	1	6		
	1/07/13	21/07/13	22/07/13	pH		Monthly	1	7.28		