

Tower Power Station

Licence Number: 5357

EDL CSM (NSW) PTY LTD
PO BOX 4046

Licence Holder: Eight Mile Plains 4113

Tower Coal Seam Methane Power Station
Douglas Park Drive

Licensee Address: Douglas Park NSW 2569

Month: Sep-13

Location of monitoring point	Sampled	Obtained	Published	Pollutant	Units of measure	Monitoring frequency required by licence	No. of times measured during month	Min. value	Mean value	Max. Value
Point 10 - Ambient air and weather monitoring station	-	14/10/13	17/10/13	Nitrogen Oxides	Parts per billion	Continuous	Continuous	1	11	161
	-	14/10/13	17/10/13	Ozone	Parts per billion	Continuous	Continuous	1	22	49
Point 11 - Air emissions monitoring	-	-	17/10/13	Nitrogen Oxides	Parts per million	Continuous	Continuous	Max NOx emission rate did not exceed 2132g/min		
Point 8 - First Flush Effluent quality monitoring	-	-	17/10/13	Oil and Grease	Milligrams per litre	Weekly during any discharge	1	No visual		
	-	-	17/10/13	pH		Weekly during any discharge	1	8.1		
Point 9 - Process Water Effluent quality monitoring	2/09/13	18/09/13	19/09/13	Oil and Grease	Milligrams per litre	Monthly	1	<3		
	2/09/13	18/09/13	19/09/13	pH		Monthly	1	6.51		