

**Teralba Power Generation Plant**

**Licence Number:** 12088

**Licence Holder:** Envirogen PTY LTD

**Licensee Address:** 1 Railway Street TERALBA NSW 2284

**Testing Month/Year:** Nov-13

Location of monitoring point	Sampled	Obtained	Published	Pollutant	Units of measure	Monitoring frequency required by licence	Licence Limit	No. of times measured during month	Min. value	Mean value	Max. Value
Point 09 - Water quality monitoring. Outlet of oil-water separator	6/11/13		3/07/14	Oil and Grease	Milligrams per litre	Monthly	0	1		7.12	
	6/11/13		3/07/14	Total suspended solids	Milligrams per litre	Monthly	<50	1		1	
	6/11/13		3/07/14	pH	pH	Monthly	6.5-8.5	1		<5	