

Tower Power Station

Licence Number: 5357

EDL CSM (NSW) PTY LTD
PO BOX 4046

Licence Holder: Eight Mile Plains 4113

Tower Coal Seam Methane Power Station
Douglas Park Drive

Licensee Address: Douglas Park NSW 2569

Month: Nov-13

| Location of monitoring point | Sampled | Obtained | Published | Pollutant | Units of measure | Monitoring frequency required by licence | No. of times measured during month | Min. value | Mean value | Max. Value |
|--|---------|----------|-----------|-----------------|----------------------|--|------------------------------------|--|------------|------------|
| Point 10 - Ambient air and weather monitoring station | - | 12/12/13 | 13/12/13 | Nitrogen Oxides | Parts per billion | Continuous | Continuous | 0 | 10 | 96 |
| | - | 12/12/13 | 13/12/13 | Ozone | Parts per billion | Continuous | Continuous | 2 | 21 | 78 |
| Point 11 - Air emissions monitoring | - | - | 13/12/13 | Nitrogen Oxides | Parts per million | Continuous | Continuous | Max NOx emission rate did not exceed 2132g/min | | |
| Point 8 - First Flush Effluent quality monitoring | - | - | 10/12/13 | Oil and Grease | Milligrams per litre | Weekly during any discharge | 1 | No visual | | |
| | - | - | 10/12/13 | pH | | Weekly during any discharge | 1 | 8.1 | | |
| Point 9 - Process Water Effluent quality monitoring | 4/11/13 | 27/11/13 | 27/11/13 | Oil and Grease | Milligrams per litre | Monthly | 1 | <3 | | |
| | 4/11/13 | 27/11/13 | 27/11/13 | pH | | Monthly | 1 | 7.42 | | |