

Tower Power Station

Licence Number: 5357

EDL CSM (NSW) PTY LTD
PO BOX 4046

Licence Holder: Eight Mile Plains 4113

Tower Coal Seam Methane Power Station
Douglas Park Drive

Licensee Address: Douglas Park NSW 2569

Month: Jan-14

Location of monitoring point	Sampled	Obtained	Published	Pollutant	Units of measure	Monitoring frequency required by licence	No. of times measured during month	Min. value	Mean value	Max. Value
Point 10 - Ambient air and weather monitoring station	-	11/02/14	13/02/14	Nitrogen Oxides	Parts per billion	Continuous	Continuous	0	6	92
	-	11/02/14	13/02/14	Ozone	Parts per billion	Continuous	Continuous	0	20	97
Point 11 - Air emissions monitoring	-	-	11/02/14	Nitrogen Oxides	Parts per million	Continuous	Continuous	Max NOx emission rate did not exceed 2132g/min		
Point 8 - First Flush Effluent quality monitoring	-	-	11/02/14	Oil and Grease	Milligrams per litre	Weekly during any discharge	2	No visual		
	-	-	11/02/14	pH		Weekly during any discharge	2	7.9	7.9	7.9
Point 9 - Process Water Effluent quality monitoring	6/01/14	20/01/14	29/01/14	Oil and Grease	Milligrams per litre	Monthly	1	<3		
	6/01/14	20/01/14	29/01/14	pH		Monthly	1	6.97		