

Teralba Power Generation Plant**Licence Number:** 12088**Licence Holder:** Envirogen PTY LTD**Licensee Address:** 1 Railway Street TERALBA NSW 2284**Testing Month/Year:** Mar-14

Location of monitoring point	Sampled	Published	Pollutant	Units of measure	Monitoring frequency required by	Licence Limit	No. of times measured	Min. value	Mean value	Max. Value
Point 09 - Water quality monitoring. Outlet of oil-water separator	31/03/14	3/07/14	Oil and Grease	Milligrams per litre	Monthly	0	1	7.14		
	31/03/14	3/07/14	Total suspended solids	Milligrams per litre	Monthly	<50	1	4		
	31/03/14	3/07/14	pH	pH	Monthly	6.5-8.5	1	<5		