

Teralba Power Generation Plant**Licence Number:** 12088**Licence Holder:** Envirogen PTY LTD**Licensee Address:** 1 Railway Street TERALBA NSW 2284**Testing Month/Year:** Dec-14

| Location of monitoring point | Sampled | Obtained | Published | Pollutant | Units of measure | Monitoring frequency required by licence | Licence Limit | No. of times measured during month | Mean value |
|---|----------|----------|-----------|------------------------|----------------------|--|---------------|------------------------------------|------------|
| Point 09 - Water quality monitoring. Outlet of oil-water separator | 19/12/14 | 16/01/15 | | Oil and Grease | Milligrams per litre | Monthly | 0 | 1 | <5 |
| | 19/12/14 | 16/01/15 | | Total suspended solids | Milligrams per litre | Monthly | <50 | 1 | 10 |
| | 19/12/14 | 16/01/15 | | pH | pH | Monthly | 6.5-8.5 | 1 | 6.78 |