

**Teralba Power Generation Plant**

**Licence Number:** 12088 (surrendered)

**Licence Holder:** Envirogen PTY LTD

**Licensee Address:** 1 Railway Street TERALBA NSW 2284

**Testing Month/Year:** FY2015/16

Month	Location of monitoring point	Sampled	Obtained	Published	Pollutant	Units of measure	Monitoring frequency	Licence Limit	No. measurements	Results
Jul-15	Point 09 - Water quality monitoring. Outlet of oil-water separator	3/08/15	14/08/15	14/08/15	O&G	mg/L	Monthly	No visible	1	<5
		3/08/15	14/08/15	14/08/15	TSS	mg/L	Monthly	<50	1	3
		3/08/15	14/08/15	14/08/15	pH		Monthly	6.5-8.5	1	6.9
Aug-15	Point 09 - Water quality monitoring. Outlet of oil-water separator	27/08/15	9/09/15	14/09/15	O&G	mg/L	Monthly	No visible	1	<5
		27/08/15	9/09/15	14/09/15	TSS	mg/L	Monthly	<50	1	2
		27/08/15	9/09/15	14/09/15	pH		Monthly	6.5-8.5	1	6.8
Sep-15	Point 09 - Water quality monitoring. Outlet of oil-water separator	29/09/15	9/10/15	15/09/15	O&G	mg/L	Monthly	No visible	1	<5
		29/09/15	9/10/15	15/09/15	TSS	mg/L	Monthly	<50	1	3
		29/09/15	9/10/15	15/09/15	pH		Monthly	6.5-8.5	1	6.5
Oct-15	Point 09 - Water quality monitoring. Outlet of oil-water separator	26/10/15	6/11/15	12/11/15	O&G	mg/L	Monthly	No visible	1	<5
		26/10/15	6/11/15	12/11/15	TSS	mg/L	Monthly	<50	1	3
		26/10/15	6/11/15	12/11/15	pH		Monthly	6.5-8.5	1	6.8
Nov-15	Point 09 - Water quality monitoring. Outlet of oil-water separator	26/11/15	7/12/15	7/12/15	O&G	mg/L	Monthly	No visible	1	<5
		26/11/15	7/12/15	7/12/15	TSS	mg/L	Monthly	<50	1	1
		26/11/15	7/12/15	7/12/15	pH		Monthly	6.5-8.5	1	6.7
Dec-15	Point 09 - Water quality monitoring. Outlet of oil-water separator	22/12/15	11/01/16	25/01/16	O&G	mg/L	Monthly	No visible	1	<5
		22/12/15	11/01/16	25/01/16	TSS	mg/L	Monthly	<50	1	2
		22/12/15	11/01/16	25/01/16	pH		Monthly	6.5-8.5	1	6.9
Jan-16	Point 09 - Water quality monitoring. Outlet of oil-water separator	28/01/16	5/02/16	22/03/16	O&G	mg/L	Monthly	No visible	1	<5
		28/01/16	5/02/16	22/03/16	TSS	mg/L	Monthly	<50	1	2
		28/01/16	5/02/16	22/03/16	pH		Monthly	6.5-8.5	1	6.5
Feb-16	Point 09 - Water quality monitoring. Outlet of oil-water separator	29/02/16	11/03/16	22/03/16	O&G	mg/L	Monthly	No visible	1	<5
		29/02/16	11/03/16	22/03/16	TSS	mg/L	Monthly	<50	1	5
		29/02/16	11/03/16	22/03/16	pH		Monthly	6.5-8.5	1	6.69
	Point 09 - Water quality monitoring	30/03/16	8/04/16	28/04/16	O&G	mg/L	Monthly	No visible	1	<5

Mar-16	<b>Point 09 - water quality monitoring. Outlet of oil-water separator</b>	30/03/16	8/04/16	28/04/16	TSS	mg/L	Monthly	<50	1	2
		30/03/16	8/04/16	28/04/16	pH		Monthly	6.5-8.5	1	6.81
Apr-16	<b>Point 09 - Water quality monitoring. Outlet of oil-water separator</b>	26/04/16	6/05/16	2/11/16	O&G	mg/L	Monthly	No visible	1	<5
		26/04/16	6/05/16	2/11/16	TSS	mg/L	Monthly	<50	1	<1
		26/04/16	6/05/16	2/11/16	pH		Monthly	6.5-8.5	1	6.46
May-16	<b>Point 09 - Water quality monitoring. Outlet of oil-water separator</b>	30/05/16	9/06/16	2/11/16	O&G	mg/L	Monthly	No visible	1	<5
		30/05/16	9/06/16	2/11/16	TSS	mg/L	Monthly	<50	1	2
		30/05/16	9/06/16	2/11/16	pH		Monthly	6.5-8.5	1	6.48
Jun-16	<b>Point 09 - Water quality monitoring. Outlet of oil-water separator</b>	26/06/16	4/07/16	2/11/16	O&G	mg/L	Monthly	No visible	1	<5
		26/06/16	4/07/16	2/11/16	TSS	mg/L	Monthly	<50	1	15
		26/06/16	4/07/16	2/11/16	pH		Monthly	6.5-8.5	1	6.58
Jul-16	<b>Point 09 - Water quality monitoring. Outlet of oil-water separator</b>	28/07/16	23/09/16	2/11/16	O&G	mg/L	Monthly	No visible	1	<5
		28/07/16	23/09/16	2/11/16	TSS	mg/L	Monthly	<50	1	2
		28/07/16	23/09/16	2/11/16	pH		Monthly	6.5-8.5	1	6.4
Aug-16	<b>Point 09 - Water quality monitoring. Outlet of oil-water separator</b>	30/08/16	23/09/16	2/11/16	O&G	mg/L	Monthly	No visible	1	<5
		30/08/16	23/09/16	2/11/16	TSS	mg/L	Monthly	<50	1	2
		30/08/16	23/09/16	2/11/16	pH		Monthly	6.5-8.5	1	6.36

Advised by Council that we are no longer required to complete water testing as the Licence has been surrendered: