

Tahmoor Power Generation Plant

Licence Number: 11768

Licence Holder: Envirogen PTY LTD

Licensee Address: Remembrance Driveway TAHMOOR NSW 2573

Testing Month/Year: 2014 Annual Emissions Testing

Location of monitoring point	Sampled	Obtained	Published	Pollutant	Units of measure	Monitoring frequency required by licence	Licence Limit	No. of times measured during month	Min. value	Mean value	Max. Value
Point 1 - Discharge to Air, Exhaust stack from gas engine 1	14/01/14	29/01/14	19/06/14	Nitrogen Oxides	milligrams per normalised cubic metre	Annually	<450 Dry 273K 101.3kPa 7% O2 1 hour average	1		403	
Point 2 - Discharge to Air, Exhaust stack from gas engine 2	14/01/14	29/01/14	19/06/14	Nitrogen Oxides	milligrams per normalised cubic metre	Annually	<450 Dry 273K 101.3kPa 7% O2 1 hour average	1		422	
Point 3 - Discharge to Air, Exhaust stack from gas engine 3	14/01/14	29/01/14	19/06/14	Nitrogen Oxides	milligrams per normalised cubic metre	Annually	<450 Dry 273K 101.3kPa 7% O2 1 hour average	1		416	
Point 4 - Discharge to Air, Exhaust stack from gas engine 4	14/01/14	29/01/14	19/06/14	Nitrogen Oxides	milligrams per normalised cubic metre	Annually	<450 Dry 273K 101.3kPa 7% O2 1 hour average	1		427	
Point 5 - Discharge to Air, Exhaust stack from gas engine 5	14/01/14	29/01/14	19/06/14	Nitrogen Oxides	milligrams per normalised cubic metre	Annually	<450 Dry 273K 101.3kPa 7% O2 1 hour average	1		349	
Point 10 - Discharge to Air, Exhaust stack from gas engine 6	14/01/14	29/01/14	19/06/14	Nitrogen Oxides	milligrams per normalised cubic metre	Annually	<450 Dry 273K 101.3kPa 7% O2 1 hour average	1		416	
Point 11 - Discharge to Air, Exhaust stack from gas engine 7	14/01/14	29/01/14	19/06/14	Nitrogen Oxides	milligrams per normalised cubic metre	Annually	<450 Dry 273K 101.3kPa 7% O2 1 hour average	1		414	