

**Tahmoor Power Generation Plant**

**Licence Number:** 11768

**Licence Holder:** Envirogen PTY LTD

**Licencee Address:** Remembrance Driveway TAHMOOR NSW 2573

**Testing Month/Year:** 2015/16/17

Month	Location of monitoring point	Sampled	Obtained	Published	Pollutant	Units of measure	Monitoring frequency required by licence	Licence Limit	No. of times measured during month	Min. value	Mean value	Max. Value	Exceedance (Yes/No)
Jul-15	Point 08 - Effluent quality monitoring - outlet of oil water separator	21/07/15	5/08/15	6/08/15	O & G	mg/L	Monthly	<10	1	<3		No	
Aug-15		27/08/15	9/09/15	14/09/15	O & G	mg/L	Monthly	<10	1	<3		No	
Sep-15		12/10/15	7/12/15	7/12/15	O&G	mg/L	Monthly	<10	1	<3		No	
Oct-15		27/10/15	7/12/15	7/12/15	O&G	mg/L	Monthly	<10	1	<3		No	
Nov-15		2/12/15	17/02/16	23/02/16	O&G	mg/L	Monthly	<10	1	<3		No	
Dec-15		3/02/16	17/02/16	23/02/16	O&G	mg/L	Monthly	<10	1	<3		No	
Jan-16		9/03/16	27/04/16	28/04/16	O&G	mg/L	Monthly	<10	1	<3		No	
Feb-16		31/03/16	27/04/16	28/04/16	O&G	mg/L	Monthly	<10	1	<3		No	
Mar-16		17/06/16	23/09/16	26/09/16	O&G	mg/L	Monthly	<10	1	<3		No	
Apr-16		27/06/16	23/09/16	26/09/16	O&G	mg/L	Monthly	<10	1	<3		No	
May-16		1/08/16	23/09/16	26/09/16	O&G	mg/L	Monthly	<10	1	<3		No	
Jun-16		6/08/16	23/09/16	26/09/16	O&G	mg/L	Monthly	<10	1	<3		No	
Jul-16		16/08/16	23/09/16	26/09/16	O&G	mg/L	Monthly	<10	1	<3		No	
Aug-16		29/08/2016	19/10/2016	2/11/2016	O&G	mg/L	Monthly	<10	1	<3		No	
Sep-16		19/09/2016	19/10/2016	2/11/2016	O&G	mg/L	Monthly	<10	1	<3		No	
Oct-16		6/10/2016			O&G	mg/L	Monthly	<10	1				
Nov-16		17/11/2016	12/01/2017	3/02/2017	O&G	mg/L	Monthly	<10	1	<3		No	
Dec-16		16/12/2016	12/01/2017	3/02/2017	O&G	mg/L	Monthly	<10	1	<3		No	
Jan-17		24/01/2017	6/02/2017	13/02/2017	O&G	mg/L	Monthly	<10	1	<3		No	
Feb-17		3/02/2017	17/03/2017	20/03/2017	O&G	mg/L	Monthly	<10	1	<3		No	
Mar-17		20/03/2017	10/04/2017	11/04/2017	O&G	mg/L	Monthly	<10	1	<3		No	
Apr-17		4/04/2017	26/04/2017	3/05/2017	O&G	mg/L	Monthly	<10	1	<3		No	
May-17		1/05/2017	19/05/2017	19/05/2017	O&G	mg/L	Monthly	<10	1	<3		No	
Jun-17		1/06/2017	21/06/2017	6/07/2017	O&G	mg/L	Monthly	<10	1	<3		No	