

Teralba Power Generation Plant

Licence Number: 12088

Licence Holder: Envirogen PTY LTD

Licensee Address: 1 Railway Street TERALBA NSW 2284

Testing Month/Year: Apr-15

Location of monitoring point	Sampled	Obtained	Published	Pollutant	Units of measure	Monitoring frequency required by licence	Licence Limit	No. of times measured during month	Mean value
Point 09 - Water quality monitoring. Outlet of oil-water separator	29/04/15	14/05/15	18/05/15	Oil and Grease	Milligrams per litre	Monthly	0	1	<5
	29/04/15	14/05/15	18/05/15	Total suspended solids	Milligrams per litre	Monthly	<50	1	2
	29/04/15	14/05/15	18/05/15	pH	pH	Monthly	6.5-8.5	1	6.64