

Teralba Power Generation Plant**Licence Number:** 12088**Licence Holder:** Envirogen PTY LTD**Licensee Address:** 1 Railway Street TERALBA NSW 2284**Testing Month/Year:** Mar-15

Location of monitoring point	Sampled	Obtained	Published	Pollutant	Units of measure	Monitoring frequency required by licence	Licence Limit	No. of times measured during month	Mean value
Point 09 - Water quality monitoring. Outlet of oil-water separator	24/03/15	8/04/15	13/04/15	Oil and Grease	Milligrams per litre	Monthly	0	1	<5
	24/03/15	8/04/15	13/04/15	Total suspended solids	Milligrams per litre	Monthly	<50	1	4
	24/03/15	8/04/15	13/04/15	pH	pH	Monthly	6.5-8.5	1	6.96