

Teralba Power Generation Plant

Licence Number: 12088

Licence Holder: Envirogen PTY LTD

Licensee Address: 1 Railway Street TERALBA NSW 2284

Testing Month/Year: May-15

Location of monitoring point	Sampled	Obtained	Published	Pollutant	Units of measure	Monitoring frequency required by licence	Licence Limit	No. of times measured during month	Mean value
Point 09 - Water quality monitoring. Outlet of oil-water separator	27/05/15	10/07/15	15/07/15	Oil and Grease	Milligrams per litre	Monthly	0	1	<5
	27/05/15	10/07/15	15/07/15	Total suspended solids	Milligrams per litre	Monthly	<50	1	1
	27/05/15	10/07/15	15/07/15	pH	pH	Monthly	6.5-8.5	1	6.48