

Tahmoor Power Generation Plant

Licence Number: 11768

Licence Holder: Envirogen PTY LTD

Licensee Address: Remembrance Driveway TAHMOOR NSW 2573

Testing Month/Year: Dec-12

Location of monitoring point	Sampled	Obtained	Published	Pollutant	Units of measure	Monitoring frequency required by licence	Licence Limit	No. of times measured during month	Min. value	Mean value	Max. Value
Point 1 - Discharge to Air, Exhaust stack from gas engine 1	18/12/14	17/07/14	21/07/14	Nitrogen Oxides	milligrams per normalised cubic metre	6 Monthly	<450 Dry 273K 101.3kPa 7% O2 1 hour average	1		404	
Point 2 - Discharge to Air, Exhaust stack from gas engine 2	18/12/14	17/07/14	21/07/14	Nitrogen Oxides	milligrams per normalised cubic metre	6 Monthly	<450 Dry 273K 101.3kPa 7% O2 1 hour average	1		406	
Point 3 - Discharge to Air, Exhaust stack from gas engine 3	18/12/14	17/07/14	21/07/14	Nitrogen Oxides	milligrams per normalised cubic metre	6 Monthly	<450 Dry 273K 101.3kPa 7% O2 1 hour average	1		291	
Point 4 - Discharge to Air, Exhaust stack from gas engine 4	18/12/14	17/07/14	21/07/14	Nitrogen Oxides	milligrams per normalised cubic metre	6 Monthly	<450 Dry 273K 101.3kPa 7% O2 1 hour average	1		403	
Point 5 - Discharge to Air, Exhaust stack from gas engine 5	18/12/14	17/07/14	21/07/14	Nitrogen Oxides	milligrams per normalised cubic metre	6 Monthly	<450 Dry 273K 101.3kPa 7% O2 1 hour average	1		447	
Point 10 - Discharge to Air, Exhaust stack from gas engine 6	Not operating at the time of testing			Nitrogen Oxides	milligrams per normalised cubic metre	6 Monthly	<450 Dry 273K 101.3kPa 7% O2 1 hour average	1	Not operating at the time of testing		
Point 11 - Discharge to Air, Exhaust stack from gas engine 7	18/12/14	17/07/14	21/07/14	Nitrogen Oxides	milligrams per normalised cubic metre	6 Monthly	<450 Dry 273K 101.3kPa 7% O2 1 hour average	1		444	